

# CERTIFICATE

TÜV NORD Systems GmbH & Co. KG, Hamburg,  
confirms


**Böllhoff Verbindungstechnik GmbH, Bielefeld:**

Duct-connections between sheet metal air ducts with rectangular sections  
and the belonging flanges manufactured with the joining tool

## RIVCLINCH<sup>®</sup>


(Type: SC 0404IP V3M AERO)

fulfill the requirements according to DIN EN 1507:2006 regarding the  
**Air tightness class D.**



Details are documented in the TÜV NORD Test Report No. 81 06 04 97 89.

TÜV NORD Systems GmbH & Co. KG  
Abteilung Gebäudetechnik



Dipl.-Ing. (FH) M. Lukas

Essen, 18. Januar 2011